Filtration Test completed on Lakos Separator Model: eHTX-0040-V

The filter assembly was installed with test components defined as follows:

1) 3” turbine-type flow meter
2) 20 micron disc filter assembly
3) 2” pipe spool with sand-injection pump
4) 1.5” pipe spool
5) Separator under test
6) 1.5” pipe spool
7) 20 micron disc filter assembly

Test Conditions: 85 US gpm, 12.0 psi loss

Media Sample	45-75 micron: 50 grams Media: Quartz, specific gravity: 2.6, Silicon Dioxide by Powder Technology Inc
Media Recovery	From downstream filters: 1.3 grams
Filter Efficiency	48.7 / 50.0 = 97.4%

Test Date: December 12, 2012

Joe C. Oliphant
Hydraulics Lab Manager

GEDO
Distribution et conseil : GEDO FRANCE
04 85 88 02 75 | separateur@gedo.fr | separateurs.gedo.fr
565 avenue du Prado - 13008 Marseille - France