Filtration Test completed on Lakos Separator Model: eJPX-0080-V

The filter assembly was installed with test components defined as follows:

1) 3” turbine-type flow meter
2) 20 micron disc filter assembly
3) 2” pipe spool with sand-injection pump
4) Separator under test
5) 2” pipe spool
6) 20 micron disc filter assembly

Test Conditions: 130 US gpm, 12.9 psi loss

Media Sample	45-75 micron: 50 grams Media: Quartz, specific gravity: 2.6, Silicon Dioxide by Powder Technology Inc
Media Recovery	From downstream filters: 0.6 grams
Filter Efficiency	49.4 / 50.0 = 98.8%

Test Date: October 19, 2012

Joe C. Oliphant
Hydraulics Lab Manager

GEDO
Distribution et conseil : GEDO FRANCE
04 85 88 02 75 | separateur@gedo.fr | separateurs.gedo.fr
565 avenue du Prado - 13008 Marseille - France